



INTEGRATED COASTAL ZONE MANAGEMENT PROJECT
State Project Management Unit (SPMU)
Gujarat Ecology Commission
Udyog Bhavan, Block No. 18, 1st Floor, Gandhinagar – 382 010, Gujarat

National Competitive Bidding (NCB)

IFB No. SPMU/GEC/NCB/03/2017-18

Dt.: 05/05/2018

Corrigendum No. 1 (Clarifications)

SUPPLYING & INSTALLATION AND COMMISSIONING OF SOLAR RENEWABLE ENERGY APPLICATION-Home lights

Details	Original Provision as per Bid Document	Modified Provision after Amendment
Page No. 60 Point No. 3 Electric Work	"Supply and installation of Earthing, grounding, lightening protection equipments"	Earthing, Grounding and Lightening protection is not required for solar home light system.
	Human safety and protection equipment including danger signs, fire-fighting system etc."	Human safety and protection equipment including danger signs, fire-fighting etc. not required in solar home light system.
Page No. 69 Clause: Detailed Specifications- Sub Clause No. 2: LED Fixtures	Construction of Fixtures: As per IP-65"	IP 65 fixtures are not required.
Page No. 71 Sub Clause No. 7: Mechanical Components	Please clarify, as is not required in solar home light system.	Pole is required for proper mounting of solar PV modules. It should also bear small nameplate in which name of GEC and ICZMP project to be mentioned, name and contact detail of contact person of contractor needs to be mentioned for ease of communication. This requirement is mandatory.